



Wisconsin Department of Agriculture, Trade and Consumer Protection
 Bureau of Weights and Measures
 P.O. Box 7837, Madison, WI 53707-7837
 (608) 224-4942

FOR OFFICE USE ONLY

UST CORROSION PROTECTION TEST/SURVEY REPORT

Wis. Admin. Code §ATCP 93.100

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).

OWNER INFORMATION				
CUSTOMER NAME:		COMPANY NAME:		TELEPHONE: () -
STREET ADDRESS:		<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN		STATE ZIP
SITE INFORMATION				
FACILITY NAME:		FACILITY ID#:		ASSIGNED ANNIVERSARY MONTH DATE OF TESTING/SERVICING
STREET ADDRESS:		<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN		STATE ZIP
TESTER INFORMATION				
SUBMITTING PARTY:		CONTACT PERSON		WORK ORDER #:
TELEPHONE: () -		CELL PHONE: () -		E-MAIL:

TESTER NAME:		SURVEY TYPE:	
Wisconsin Certification Type:		<input type="checkbox"/> Routine <input type="checkbox"/> Re-Survey <input type="checkbox"/> Post-Repair or Modification <input type="checkbox"/> Post-Installation	
Wisconsin Certification #:		TYPE OF SYSTEM: <input type="checkbox"/> Impressed Current <input type="checkbox"/> Galvanic	
CP CRITERION APPLIED:	<input type="checkbox"/> -0.850 volts "ON" (Galvanic)	<input type="checkbox"/> 100 mV Polarization (Impressed)	<input type="checkbox"/> -0.850 volts "INSTANT-OFF" (Impressed)
SECTION I: Tester's evaluation (mark only one)			
<input type="checkbox"/> PASS	All protected structures at this site pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. Complete Section III.		
<input type="checkbox"/> FAIL	One or more protected structures at this site fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system. Complete Section III.		
<input type="checkbox"/> INCONCLUSIVE	If the remote and the local do not both indicate the same test result on all protected structures (both pass or both fail), inconclusive is indicated and the survey must be evaluated and/or conducted by a corrosion expert. Go to Section II.		

CP TESTER (Print):

CP TESTER'S SIGNATURE:

SECTION II: Corrosion expert's evaluation (mark only one)	
The survey must be conducted and/or evaluated by a corrosion expert when: a) supplemental anodes or other changes in the cathodic protection system are made; b) stray current may be affecting buried metallic structures or c) an inconclusive result was indicated.	
<input type="checkbox"/> PASS	All protected structures at this site pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. Complete Section III.
<input type="checkbox"/> FAIL	One or more protected structures at this site fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system. Complete Section III.
COMMENT:	

CORROSION EXPERT'S NAME (Print):

CORROSION EXPERT'S NAME

COMPANY NAME:		WISCONSIN CORROSION EXPERT CERTIFICATION #:		REVIEW DATE:	
STREET ADDRESS:		CITY		STATE	ZIP
SECTION III: Action required as a result of this evaluation (mark only one)					
<input type="checkbox"/> NONE		Cathodic protection is adequate. Test again within regulatory window or by:		(DATE):	
<input type="checkbox"/> REPAIR & RETEST		Cathodic protection is not adequate. (Corrosion Expert evaluation in Section II is required if adding supplemental anodes, impressed current, or if stray current is suspected.) Repair/modification is necessary by:		(DATE):	
<input type="checkbox"/> TESTING INDICATES INCONCLUSIVE		Wisconsin Corrosion Expert evaluation required within 30 days :		(DATE):	

[illegible]

[illegible]

Provide a drawing or use the space below:

- NOTES:** 1) Measurements shall be taken over tank(s); Minimum 3 tank top/ 1 remote.
2) One measurement shall be taken for every 10 feet of piping length.

Include Service Station Diagram that shows all Tanks and Dispensers in relation to Buildings and Streets. Include on the drawing the location of the Submersible Pumps, Fills, ATGs, Risers, and Vents. If this is an Impressed Current System, show Rectifier location. Clearly indicate on diagram where all Test Readings were taken by identifying each structure being tested (UST by Product Stored or Product Piping by Tank/Dispenser) and numbering each individual test location. Show on drawing if corrosion test leads and/or test stations exist for the USTs or product piping and their location. Show locations of all reference electrodes. Indicate **North** on the drawing.